HSS/SS Stud Shoes

SIMPSON

Stud Shoes reinforce studs notched in construction. They are NOT a total replacement of removed material. Installs over pipe up to 2%" outside diameter. HSS2-3 is designed for triple 2x studs.

HSS Stud Shoes provide tension load capacity as well as increased compression loads. Flared flange provides greater strength.

MATERIAL: 16 gauge FINISH: Galvanized

INSTALLATION: Use all specified fasteners. See General Notes.

- HSS: Bend flanges at 90° angle during installation, then bend back and screw into position (screws supplied).
- · Bend flanges one cycle only.

CODES: See page 12 for Code Reference Key Chart.

HSS2-SDS1.5 (16 gauge) Heavy stud shoes to reinforce and protect single 2x studs where pipe is located. Uses 12 Simpson Strong-Tie® Strong-Drive® $\frac{1}{4}$ "x1 $\frac{1}{2}$ " screws (SDS) (included).

- IRC 2006 R602.6 and P2603.2.1
- IBC 2006 2308.9.10 & 2308.9.11
- IPC 2000/2003/2006 305.8

HSS2-3-SDS3 (16 gauge) Heavy stud shoe for triple 2x stud. Uses 12 Simpson Strong-Tie SDS 1/4"x2" screws (included).


- IRC 2006 R602.6 and P2603.2.1
- IBC 2006 2308.9.10 & 2308.9.11
- IPC 2006 305.8

SS1.5 (16 gauge) stud shoes reinforce and protect plumbing in 2x.


- IRC 2006 R602.6 and P2603.2.1
- IBC 2006 2308.9.10 & 2308.9.11
- IPC 2006 305.8

			Allo				
Model No.	Stud Size	Fasteners		Code			
			Compr	ession	Tension	Ref.	
			Floor (100)	Roof (125)			
SS1.5	2x	12-10dx1½	500	500	_	116, F15	
SS2.5	3x	12-10dx1½	500	500	_		
SS3	2-2x	12-10d	665	785	_		
SS4.5	3-2x	14-10d	665	785	_		
HSS2-SDS1.5	2x	12-SDS 1/4"x11/2"	1200	1200	1000		
HSS2-2-SDS3	2-2x	12-SDS 1/4"x3"	1200	1200	1000		
HSS2-3-SDS3	3-2x	12-SDS 1/4"x3"	1000	1000	970		
HSS4-SDS3	4x	12-SDS 1/4"x3"	1200	1200	1000		


- 1. Roof loads are 125% of floor loads unless limited by other criteria. Floor loads may be adjusted for other load durations according to the code, provided they do not exceed roof loads.
- 2. **NAILS:** 10d = 0.148" dia. x 3" long, $10dx1\frac{1}{2} = 0.148$ " dia. x $1\frac{1}{2}$ " long. See page 16-17 for other nail sizes and information.








HSS2-3



STEP 1 Install HSS (HSS2-3 shown) over stud with flanges bent at a 90° angle.



STEP 2 Bend HSS (HSS2-3 shown) flanges one time only. Screw into position.



Typical SS3 Installation Typical SS1.5

Installation

C-2009 © 2008 SIMPSON STRONG-TIE COMPANY INC. PRINTED 12/08

RPS Strap Ties

The RPS meets IBC, IRC and City of Los Angeles code requirements for HVAC and pipes in walls.


FINISH: Galvanized, some products available in ZMAX® coating. See Corrosion Information, page 10-11.

INSTALLATION: Use all specified fasteners. See General Notes.

CODES: See page 12 for Code Reference Key Chart.

Use RPS22 or RPS28 (16 gauge) to reinforce top plate. Use RPS18Z, RPS22Z or RPS28Z (16 gauge ZMAX) to reinforce sill plate.


- International Residential Code®- 2006 R602.6.1
- International Building Code®- 2006 2308.9.8




	Model No.	Ga	Dimensions		Notch Width	Fasteners (Total)	Allowable Tension Loads (DF/SP)	Allowable Tension Loads (SPF/HF)	Code Ref.	
	140.		W	L	wiutii	Nails	(160)	(160)	1101.	
	RPS18		11/2	185/16	≤ 5½"	12-16d	1380	1190	l16, L25, F15	
	RPS22	16	11/2	225/16	≤5½"	12-16d	1380	1190		
			11/2	225/16		16-16d	1805	1585		
R	RPS28		11/2	285/16	≤ 12"	12-16d	1380	1190		
			11/2	285/16		16-16d	1805	1585		

- 1. Loads include a 60% load duration increase on the fasteners for wind or earthquake loading.
- 2. To meet the prescriptive IRC requirement 10dx1½ (0.148" dia. x 1½" long) may be used.

3. **NAILS:** 16d = 0.162" dia. x $3\frac{1}{2}$ " long. See page 16-17 for other nail sizes and information.





Typical RPS Installation (Only one strap may be necessary to meet IRC requirements)