



SPECIFICATION: BLÜCHER PIPE AISI Type 316L (standard) stainless steel pipe system, with Push-Fit socket connections with EPDM (standard) sealing ring. All BLÜCHER PIPE to be treated with pickling and passivation finish process.




Eccentric Increaser Dimensional Chart

Model No.	D	D1	X	X5
EI-3x2-316	3"(75)	2"(50)	3-1/4"(82)	5/16"(7)
EI-4x2-316	4"(110)	2"(50)	4-5/16"(108)	1"(25)
EI-4x3-316	4"(110)	3"(75)	4-3/8"(111)	5/8"(15)
EI-6x3-316	6"(160)	3"(75)	6-3/4"(172)	1-1/2"(37)
EI-6x4-316	6"(160)	4"(110)	5-11/32"(135)	7/8"(22)



Concentric Increaser Dimensional Chart

Model No.	D	D1	X
CI-3x2-316	3"(75)	2"(50)	3-1/16"(77)
CI-4x2-316	4"(110)	2"(50)	3-9/16"(89)
CI-4x3-316	4"(110)	3"(75)	3-9/16"(90)
CI-5x4-316	5"(125)	4"(110)	3-7/8"(98)
CI-6x4-316	6"(160)	4"(110)	4-7/16"(112)
CI-6x5-316	6"(160)	5"(125)	5-9/16"(140)
CI-8x6-316	8"(200)	6"(160)	6-7/16"(164)
CI-10x8-316	10"(250)	8"(200)	6-5/8"(168)



Eccentric Reducer Dimensional Chart

Model No.	D	D1	X	X5
ER-2x3-316	2"(50)	3"(75)	3-1/8"(79)	5/16"(7)
ER-2x4-316	2"(50)	4"(110)	3-3/4"(94)	1"(25)
ER-3x4-316	3"(75)	4"(110)	3-7/8"(98)	5/8"(15)
ER-4x6-316	4"(110)	6"(160)	4-5/8"(117)	7/8"(22)

Job Name _____ Contractor _____

Job Location _____ Approval _____

Engineer _____ Contractor's P.O. No. _____

Approval _____ Representative _____