

GRUVLOK STAINLESS STEEL FITTINGS - TYPE 316



Gruvlok Schedule 10 Stainless Steel Fittings are segmentally welded with ends grooved to Gruvlok specifications. The standard material is 316 Stainless Steel unless otherwise noted with 304SS and/or Schedule 40 optional. Installation is quick and easy with the Gruvlok Figure 7400SS Coupling, or other Gruvlok product.

FIG. 7050SS

90° Stainless Steel Elbow
Type 316




FIGURE 7050SS 90° STAINLESS STEEL ELBOW		
Nominal Size	Center to End*	Approx. Wt. Ea.
In./DN(mm)	In./mm	Lbs./Kg
1¼ 32	3¾ 98	1.2 0.5
1½ 40	4¼ 108	1.4 0.6
2 50	4¾ 111	2.3 1.0
2½ 65	5¼ 146	3.3 1.5
3 80	5⅞ 149	4.6 2.1
4 100	7½ 191	7.9 3.6
6 150	10¾ 273	17.0 7.7
8 200	15 381	29.4 13.4
10 250	18 457	41.8 18.9
12 300	21 533	46.5 21.1

FIG. 7051SS

45° Stainless Steel Elbow
Type 316




FIGURE 7051SS 45° STAINLESS STEEL ELBOW		
Nominal Size	Center to End*	Approx. Wt. Ea.
In./DN(mm)	In./mm	Lbs./Kg
1¼ 32	2½ 64	0.7 0.3
1½ 40	2½ 64	0.9 0.4
2 50	2½ 64	1.5 0.7
2½ 65	3 76	1.9 0.9
3 80	3⅞ 86	3.3 1.5
4 100	4 102	5.4 2.4
6 150	5½ 140	11.2 5.1
8 200	7¼ 184	19.8 9.0
10 250	8½ 216	21.0 9.5
12 300	10 254	23.0 10.4

FIG. 7060SS

Stainless Steel Tees
Type 316




FIGURE 7060SS STAINLESS STEEL TEE		
Nominal Size	Center to End*	Approx. Wt. Ea.
In./DN(mm)	In./mm	Lbs./Kg
1¼ 32	2¾ 70	1.5 0.7
1½ 40	2¾ 70	1.8 0.8
2 50	3¼ 83	2.4 1.1
2½ 65	3¾ 95	4.0 1.8
3 80	4¼ 108	5.8 2.6
4 100	5 127	10.3 4.7
6 150	6½ 165	25.7 11.7
8 200	7¾ 197	41.1 18.6
10 250	9 229	36.0 16.3
12 300	10 254	48.4 22.0

FIG. 7074SS

Stainless Steel Caps
Type 316




FIGURE 7074SS STAINLESS STEEL CAP		
Nominal Size	Center to End*	Approx. Wt. Ea.
In./DN(mm)	In./mm	Lbs./Kg
1¼ 32	1⅝ 41	0.4 0.2
1½ 40	1⅝ 41	0.5 0.2
2 50	1⅝ 41	0.8 0.4
2½ 65	1¾ 45	1.1 0.5
3 80	1¾ 45	1.6 0.7
4 100	1¾ 45	2.8 1.3
6 150	1⅞ 48	3.7 1.7
8 200	2¼ 57	8.8 4.0
10 250	2¼ 57	12.1 5.5
12 300	2¼ 57	17.3 7.8

Notes:

- 1) *Dimensions may differ from those shown above. Contact an Anvil Representative for more information.
- 2) Fabricated fittings weights are based on Schedule 10 pipe.
- 3) Fabricated Schedule 10, 316SS and Schedule 40 Center to End dimensions are the same.
- 4) The pressure rating for the Gruvlok Schedule 10 Stainless Steel Fittings are equal to the pressure rating of the coupling used on Schedule 10 pipe as shown in the Working Pressure Ratings Chart for Stainless Steel Roll Grooved Pipe on page 143.