

FIRE-RATED CABINETS



The First Cabinets Classified and Listed by Underwriters Laboratories, Inc.



- **UL CLASSIFIED LISTING NO. 7N43 ANSI/UL 1479**
- **RATED FOR 1 & 2 HOUR WALL SYSTEMS**
- **HEAVY GAUGE, COLD-ROLLED STEEL CONSTRUCTION**
- **CORROSION RESISTANT POLYESTER POWDER-COATED FINISH**

Potter Roemer proudly offers the industry's first fire-rated extinguisher and valve cabinets classified and listed by Underwriters Laboratories, Inc. Available as an option on the majority of

Potter Roemer models, Underwriters Laboratories, Inc. has classified and listed our fire-rated option for 1- and 2-hour combustible and non-combustible wall assemblies.

By specifying the fire-rated option, you can eliminate the extra expense of lining wall openings, maintain the integrity of wall penetrations and ensure compliance with stringent building codes.


SPECIFICATION

Fire extinguisher cabinet shall be Model No. FRC _____. Underwriters Laboratories, Inc. Classified No. 7N43 2-hour Fire-Rated unit as manufactured by Potter Roemer, Santa Ana, CA, 800-366-FIRE. Install the cabinet plumb and level, where indicated on the drawings, at heights acceptable to the authority having jurisdiction. Each cabinet shall have a Potter Roemer Model No. _____ fire extinguisher installed inside.

TO SPECIFY

Refer to cabinet pages 6-12. Add the prefix **FRC-** to any Model No. indicated in the dimensions table column headed "FRC Available".

Call Potter Roemer for current listings and approvals. Dimensions are subject to manufacturer's tolerance and change without notice. We assume no responsibility for use of superseded or void data.



Dual-wall construction with Fire-Rated material between