COPPER TUBING HANGERS

Fig. 69F

Adjustable Swivel Ring, Felt Lined

Size Range: 1/2" through 6" copper tube

Material: Carbon steel and felt with adhesive backing

Finish: Galvanized

Service: Recommended for suspension of non-insulated stationary copper tubing.

Maximum Temperature: 120° F

Approvals: Complies with Federal Specification A-A-1192A (Type 10) *WW-H-171-E (Type 10)*, ANSI/MSS SP-69 and MSS SP-58 (Type 10).

Features:


- The layer of felt separates the copper tubing from the steel ring for electrolytic resistance and also minimizes noise and vibration.
- Threads are countersunk so they cannot become burred or damaged.
- Knurled swivel nut provides vertical adjustment after tubing is in place.
- The captured nut is permanent in the bottom portion of band, allowing the hanger to be opened during installation if desired, but not allowing the nut to fall out.

Ordering: Specify felt ring size, figure number and name.



→ A	<u> </u>
F C	B
G	

 $\frac{1}{2}$ " & $\frac{3}{4}$ " tube $\frac{1}{2}$ " through 1" Felted Ring



1" through 6" tube 11/4" through 6" Felted Ring

FELT LINED RING: IPS SIZING • DIMENSIONS (IN)					
Pipe Size	Felted Ring Size				
1/2	1/2 - 1				
3/4	11/4				
1	11/4				
11/4	2				
1½	2				
2	2½				
21/2	3				
3	4				
4	5				

5

FIG. 69F: LOADS (LBS) • WEIGHT (LBS) • DIMENSIONS (IN)									
Tube Size	Felted Ring Size	Max Load	Rod Size A	В	С	F	G Width	Weight	
1/2	1/ 4			23/4	17/8	13/8		0.10	
3/4	1/2 - 1			2 5// ₈	1 ¹¹ / ₁₆	11/8	1	0.10	
1	11/4	200		2 ⁷ / ₁₆	1%6	1 ¹³ / ₁₆	5./	0.10	
11/4		300		2 ½	15/8	¹³ / ₁₆	5/8	0.10	
11/2	1½		3/8	2 5// ₈	13/4	3/4		0.10	
2	2			31//8	21/4	1		0.10	
2 ½	21/2	525 650		37/8	25/8	113/		0.20	
3	3			3¾	27/8	1 13/16		0.20	
4	4] [4 5⁄/ ₈	33/4	1%16	3/4	0.30	
5	5	1,000	1/	51/4	4 ⁵ ⁄ ₁₆	15/8	1	0.54	
6	6		1/2	611/16	5%	23/8	1	0.65	

ANVIL® INTERNATIONAL

www.anvilintl.com

23

PH-11.11

Contents

ng Gener

Copper Tub Hangers

> Stainless Stee Hangers

> > CF VC Pipe Hangers

Rings

Hang

Clamps

Clamps

bea ts Clarr

Structi

ng Plates B

6