

Forged Steel Fittings

Class 3000 Socket Weld





FIGURE 2158 Laterals	Size		B		C		D		K		L		Unit Weight	
	NPS	DN	in	mm	in	mm	in	mm	in	mm	in	mm	lbs	kg
		½	15	1.31	33.27	0.855	21.72	0.375	8.89	2.125	54.66	3.000	76.20	1.00
	¾	20	1.56	39.62	1.065	27.05	0.500	12.70	2.563	65.10	3.563	90.50	1.50	0.68
	1	25	1.84	46.74	1.330	33.78	0.500	12.70	3.000	76.2	4.125	104.78	2.38	1.07
	1¼	32	2.22	56.39	1.675	41.91	0.500	12.70	3.500	88.90	4.813	122.25	3.75	1.69
	1½	40	2.50	63.50	1.915	49.53	0.500	12.70	3.938	100.03	5.375	135.89	4.13	1.91
	2	50	3.03	79.96	2.406	61.11	0.625	16.51	4.750	120.65	6.438	163.53	6.29	2.83

FIGURE 2154 Couplings	Size		B Socket Dia.		C Minimum		D Bore Dia.		E		J Socket Depth Minimum		Unit Weight	
	NPS	DN	in	mm	in	mm	in	mm	in	mm	in	mm	lbs	kg
		½	6	.440 .420	11.2 10.8	0.125	3.18	.299 .239	7.6 6.1	0.25	6.5	0.38	9.5	0.08
	¾	8	.575 .555	14.6 14.2	0.130	3.30	.394 .334	10.0 8.5	0.25	6.5	0.38	9.5	0.10	0.05
	¾	10	.710 .690	18.0 17.6	0.138	3.50	.523 .463	13.3 11.8	0.25	6.5	0.38	9.5	0.16	0.07
	½	15	.875 .855	22.2 21.8	0.161	4.09	.652 .592	16.6 15.0	0.38	9.5	0.38	9.5	0.21	0.10
	¾	20	1.085 1.065	27.6 27.2	0.168	4.27	.854 .794	21.7 20.2	0.38	9.5	0.50	12.5	0.40	0.18
	1	25	1.350 1.330	34.3 33.9	0.196	4.98	1.079 1.019	27.4 25.9	0.50	12.5	0.50	12.5	0.55	0.25
	1¼	32	1.695 1.675	43.1 42.7	0.208	5.28	1.410 1.350	35.8 34.3	0.50	12.5	0.50	12.5	0.75	0.34
	1½	40	1.935 1.915	49.2 48.8	0.218	5.54	1.640 1.580	41.6 40.1	0.50	12.5	0.50	12.5	1.10	0.50
	2	50	2.426 2.406	61.7 61.2	0.238	6.04	2.097 2.037	53.3 51.7	0.75	19.0	0.62	16.0	1.65	0.75
	2½	65	2.931 2.906	74.4 73.9	0.302	7.67	2.529 2.409	64.2 61.2	0.75	19.0	0.62	16.0	3.25	1.47
	3	80	3.560 3.535	90.3 89.8	0.327	8.30	3.128 3.008	79.4 76.4	0.75	19.0	0.62	16.0	5.10	2.31
	4	100	4.570 4.545	115.7 115.2	0.368	9.35	4.086 3.966	103.8 100.7	0.75	19.0	0.75	19.0	7.50	3.40

Note: When the pipe is seated against the bottom of the socket prior to welding, to prevent possible cracking of the fillet welds, it is recommended that the pipe be withdrawn approximately ¼ in (1.6mm) away from contact with the bottom of the socket before starting the weld.

Average of socket wall thickness around periphery shall be no less than listed values. The minimum values are permitted in localized areas.