



UNITED BRASS WORKS, INC.
 714 S. Main St., Randleman, NC 27317
 Tel: 800-334-3035 Fax: 800-498-4696 www.ubw.com



Model 226UT Y-Blow Down Valve

Complies with MSS-SP-80-97

200 WSP @ 406° Max • 400 WOG

Non-Shock Service • 100% Pressure Tested

Threaded Ends • Rising Stem • Swivel Disc Holder

PTFE Disc • Integral Seat

Care must be taken in blow down piping so that no water hammer effect causes shock to the "Y" blow down valve, especially in cases where a boiler has two blow down lines. In such cases both lines should be piped to a common set of blow down valves or each blow off line should be piped separately to the blow down separator. Excessive water hammer or shock can destroy valves and piping and could cause injury.

MATERIAL LIST

NO.	DESCRIPTION	MATERIAL
1	Jam Nut	Steel ASTM A563
2	Hand Wheel	Aluminum / DI
3	Stem	Naval Brass ASTM B21
4	Packing Nut	Brass ASTM B16
5	Packing Gland	Brass ASTM B16
6	Packing	Neop. Asb. Free Graph.
7	Bonnet	Bronze ASTM B62
8	Bonnet Nut	Bronze ASTM B62
9	Lock Nut	Brass ASTM B16
10	Disc Holder	Brass ASTM B62
11	Body	Bronze ATM B62
12	Marker Disc	Aluminum ASTM B209
13	Disc Nut	Brass
14	Disc	PTFE

Size	1"	1¼"	1½"	2"
A	4.75	5.56	6.25	7.75
B	5.75	7.00	7.75	8.75
Ship Wt. (lbs.)	4.20	6.10	9.00	15.00
Qty. Unit Pack	4	4	2	2

